

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Sub Divisional Engineer  
(Name of Officers with designation) from W/S & Sanitation Sub Division Phagwara  
inspected the GDR Convent Sr. Sec. School, Hoshiarpur Road, Phagwara  
(Name & Address of the school) on 22.06.2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. DWTLKPT/2425/02854 dated 27.06.2024  
of Water Testing Lab, Kapurthala (PHED Lab) certified that the  
GDR Convent Sr. Sec. School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the  
hygienic sanitation condition in the school building & the campus as per norms prescribed by the  
Central/ State/ U.T. Govt.

This certificate is valid till 30 June, 2025

Signature with Seal

Name

Designation

Name & Address of the Office / Department

Sub Divisional Engineer  
Phagwara

Sub Divisional Engineer  
W/S & Sanitation Sub Div  
Phagwara

To GDR Convent Sr. Sec. School  
Hoshiarpur Road, Phagwara  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Attested

Attested

Rupa Sharma

Manager

GDR Convent Sr. Sec. School  
Hoshiarpur Road, Rawalpindi,  
Phagwara

64 |

Principal  
GDR Convent Sr. Sec. School  
Phagwara

**DISTRICT WATER TESTING LABORATORY, KAPURTHALA**

Near Dhaliwal dona, water works, Kapurthala  
dwtlkpt@gmail.com

To,

GDR CONVENT SR. SEC SCHOOL (HOSHIARPUR ROAD)  
PHAGWARA

No.: DWTLKPT/2425/00054 Dated : 27/06/2024

Subject : Testing Reports of Water Samples.


Reference: Your Letter/SRF No. 786 Dated: 17/06/2024


As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 18/06/2024. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Kapurthala

D/A : Test Report



**Authorized Signatory**  
For, District water Testing Laboratory  
Kapurthala

*Attested*  
  
Principal  
GDR Convent Sr. Sec. School  
Phagwara

*Attested*  
  
Manager  
GDR Convent Sr. Sec. School  
Hoshiapur Road, Rawalpindi,  
Phagwara

## DISTRICT WATER TESTING LABORATORY, KAPURTHALA


Near Dhaliwal dona, water works, Kapurthala  
dwtlkpt@gmail.com


TEST REPORT			
Name & Address of Customer : <b>GDR CONVENT SR. SEC SCHOOL (HOSHIARPUR ROAD) PHAGWARA</b>		Customer Reference No.	No : 786 Dated : 17/06/2024
		Sample Submitted by	MR. ASHISH
		Date of Sample Receipt	18/06/2024
		Analysis Starting Date	26/06/2024
		Analysis completion Date	27/06/2024
Discipline : <b>Chemical Testing, Bacteriological Testing</b>		Group: <b>Water</b>	
ULR No.:		Sample Type :	Water
Test Report No.:	DWTLKPT/2425/00054	Date of Issue :	27/06/2024
Registration no.:	DWTLKPT/REG2425/00154	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	PHAGWARA / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Phagwara	District :	Kapurthala
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.91	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	130	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	90.62	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	80	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium(Ca)	17.63	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium(Mg)	8.74	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	8.93	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
12	Bacteriological Contamination(B)	ABSENT			--	H2S Vial


This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

*Attested*  
  
Principal  
GDR Convent Sr. Sec. School  
Phagwara

*Attested*  
  
Manager  
GDR Convent Sr. Sec. School  
Hoshiapur Road, Rawalpindi,  
Phagwara

Reviewed and Approved By



Mr. Jivesh Kumar  
Quality Manager  
Authorized Signatory  
For, District water Testing Laboratory  
Kapurthala

End of the Test Report